### **FPC** series

### Family of multifunctional numerical relay





## History

- 1946 Iskra Company is founded
- > 1947 First switchgear is developed in Kranj
- 1964 Railway department is formed
- 1991 Slovenia proclaims independence
- Company is renamed and reformed into Iskra d.d.
- We continue to provide technological advance solutions







### Our strength comes from our knowledge



### **Company presentation**

- Among the largest 40 Slovenian exporters
- More than 1100 employees
- ▶ 81 R&D employees
- Almost 70 years of tradition
- Annual sales 97.4 million EUR in 2013
- ► Gross turnover 99.8 million EUR in 2013



## Fields of Work

### • ENERGY SECTOR

- EFFICIENT INSTALLATIONS
- ELECTROTECHNICAL COMPONENTS
- TRAFFIC
- TELECOMMUNICATIONS
- IT & BUSINESS SOLUTIONS
- MAINTENANCE & MANAGEMENT
- SERVICES



## **Major Customers**



### **Energy sector**

- Automation of power plants
- Production and development of relays, comunication equipment,
- Protection and control in distribution and industry



## NEO 3000 Series of protection relays

### FPC 200 series

Current protections for Substation, Transformer and Motor Voltage and frequency protections for Busbar Usual applications

### FPC 400 series

Current, Voltage and Frequency protections for Substations, Transformers, Generators, Capacitors, Busbars and Motors Demanding applications

### FPC 680 series

Current, Voltage and Frequency protections for Substations, Transformers, Generators, Capacitors, Busbars and Motors Custom applications



### FPC 680

### FPC 680i







# Enchanced Local display Unit



### Rear panel configuration

154 Digital Inputs



### 12 Analog Inputs

- 0 8x current 0 - 4x voltage
- 0 5x current 0 - 7x voltage

Analog Input DC



## Measuring and Metering

- Current, voltage, power, frequency and power factor
- Active and reactive energy
- Power quality measurement
- External energy metering
- Symmetrical sequence components calculation
- Disturbance recording



## Communication





# Communication Supported protocols

- IEC 61850 (MMS+Goose)
- ▶ IEC 60870-5-101
- ▶ IEC 60870-5-103
- ▶ IEC 60870-5-104
- DNP3
- Modbus RTU
- Modbus RTU over TCP
- Modbus TCP



### Industrial FPC 680i







### Supported protection functions





## Software types

Current		Current and voltage	
F01	Basic protections	F03	Basic protections
M01	Motor protection	F04	Synchro-check
T01	Transformer protection	F05	Shunt protection
Voltage		F06	IuB protection
F02	Basic protections	F07	Differential protection
		M03	Motor protection
		T03	Transformer protection

### Configure device with PSM





### Numerical and graphical PSM software





### **KEMA** certificate for 61850



#### IEC 61850 Certificate Level A<sup>1</sup>

Page 1/2

International Usersgroup

No. 74100480-MOC/INC 11-1589

Issued to: Iskra Sistemi, d.d. Stegne 21 Ljubljana 1000 Slovenia

For the product: NEO 3000 FPC 680 Hardware version: FPC 680-F03 Software version: 1.0



The product has not shown to be non-conforming to:

#### IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "FPC880\_PICS.doc ver. 1.3", FPC880\_MICS.doc ver. 1.1", "FPC880\_TICS.doc ver. 1.0" and information for testing: "FPC880\_PIXIT.doc ver. 1.9".

The following IEC 81850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2b):

1 Basic Exchange (20/24) 2 Data Sets (3/8) 2+ Data Set Definition (23/23) 5 Unbuffered Reporting (15/18) 6 Buffered Reporting (17/20)	9a GOOSE Publish (8/12) 9b GOOSE Subscribe (10/10)   12a Direct Control (7/11) 121 Intranced SBO Control (12/19)   13 Time Synchronization (4/5) 140
---	--

This Certificate includes a summary of the test results as carried out at Iskra Sistemi in Slovenia with UniCAsim 61850 version 3.23.02 with test suite 3.23.00 and UniCA 61860 analyzer 4.21.03. The test is based on the UCA International Users Group Device Test Procedures version 2.2b. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 74100480-MOCINC 11-1588 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to KEMA by Iskra Sistemi. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, June 15 2011

M Ad Regional Director Management & Operations Consulting

R.S. Massink Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright & KEMA Nederland B.V., Amhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convertience purposes only. It is prohibited to update or change It in any mammer whatboever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original persion, the original persion.

KEMA Nederland B.V. T +31 26 356 20 25 F +31 26 351 36 83 sales@kema.com www.kema.com

### More information

### www.iskra.eu

Power division director:

Tomaž Bastar

- Tel.: +386 1 500 42 04
- E-mail: tomaz.bastar@iskra.eu
- Technical information:

Anže Bizjan

Tel.: +386 41 318 698

E-mail: anze.bizjan@iskra.eu

